

Baustellenliste

| Kreisliste | | | | | | | | | |
|------------|---------------------|---------------|------|----------------|--------------|-----------|--|-----------------|--------------------|
| Ort | Raumname | Systembauteil | VA | A | Typ / Muster | Rohrlänge | Einstellung Ventil / Durchflussregler / Pumpe | Dämmkennzeichen | Einzelraumregelung |
| | | | cm | m ² | | | | | |
| 01/01 | Zimmer 2 Nord | FBH01 | 16.5 | 17.57 | A / S | 103.7 | 1.2 l/min | u1 | 1 |
| 01/02 | Zimmer 1 Nord | FBH01 | 11.0 | 13.27 | A / S | 116.8 | 1.0 l/min | u1 | 1 |
| 01/03 | Bad Nord | FBH01 | 5.5 | 6.81 | A / S | 119.9 | 1.0 l/min | u1 | 1 |
| 01/04 | Diele Nord | FBH01 | 16.5 | 7.44 | A / S | 43.9 | 0.3 l/min | u1 | 1 |
| 01/05 | Wohnen Nord | FBH01 | 5.5 | 6.62 | A / S | 116.6 | 1.0 l/min | u1 | 1 |
| | | FBH01 | 5.5 | 6.62 | A / S | 116.6 | 1.0 l/min | u1 | 1 |
| | | FBH01 | 5.5 | 6.62 | A / S | 116.6 | 1.0 l/min | u1 | 1 |
| | | FBH01 | 5.5 | 6.62 | A / S | 116.6 | 1.0 l/min | u1 | 1 |
| 01/06 | Zimmer 2 Süd | FBH01 | 5.5 | 5.21 | A / S | 91.8 | 0.5 l/min | u1 | 1 |
| | | FBH01 | 5.5 | 5.21 | A / S | 91.8 | 0.5 l/min | u1 | 1 |
| | | FBH01 | 5.5 | 5.21 | A / S | 91.8 | 0.5 l/min | u1 | 1 |
| 01/07 | Zimmer 1 Süd | FBH01 | 5.5 | 4.74 | A / S | 83.4 | 0.6 l/min | u1 | 1 |
| | | FBH01 | 5.5 | 4.74 | A / S | 83.4 | 0.6 l/min | u1 | 1 |
| | | FBH01 | 5.5 | 4.74 | A / S | 83.4 | 0.6 l/min | u1 | 1 |
| 01/08 | Bad Süd | FBH01 | 5.5 | 4.47 | A / S | 78.7 | 0.6 l/min | u1 | 1 |
| 01/09 | Diele Süd | FBH01 | 16.5 | 7.32 | A / S | 43.2 | 0.3 l/min | u1 | 1 |
| 01/10 | Wohnen Süd | FBH01 | 5.5 | 6.49 | A / S | 114.3 | 1.2 l/min | u1 | 1 |
| | | FBH01 | 5.5 | 6.49 | A / S | 114.3 | 1.2 l/min | u1 | 1 |
| | | FBH01 | 5.5 | 6.49 | A / S | 114.3 | 1.2 l/min | u1 | 1 |
| | | FBH01 | 5.5 | 6.49 | A / S | 114.3 | 1.2 l/min | u1 | 1 |
| 02/05 | Kochen/ Wohnen Nord | FBH01 | 11.0 | 10.01 | A / S | 88.1 | 1.2 l/min | u1 | 1 |
| | | FBH01 | 11.0 | 10.01 | A / S | 88.1 | 1.2 l/min | u1 | 1 |
| | | FBH01 | 11.0 | 10.01 | A / S | 88.1 | 1.2 l/min | u1 | 1 |
| 02/10 | Kochen/Wohnen Süd | FBH01 | 5.5 | 5.90 | A / S | 103.9 | 0.8 l/min | u1 | 1 |
| | | FBH01 | 5.5 | 5.90 | A / S | 103.9 | 0.8 l/min | u1 | 1 |
| | | FBH01 | 5.5 | 5.90 | A / S | 103.9 | 0.8 l/min | u1 | 1 |
| | | FBH01 | 5.5 | 5.90 | A / S | 103.9 | 0.8 l/min | u1 | 1 |
| | | FBH01 | 5.5 | 5.90 | A / S | 103.9 | 0.8 l/min | u1 | 1 |
| 02/11 | Zimmer 2 Nord | FBH01 | 16.5 | 17.57 | A / S | 103.7 | 1.2 l/min | u1 | 1 |
| 02/12 | Zimmer 1 Nord | FBH01 | 11.0 | 13.27 | A / S | 116.8 | 1.0 l/min | u1 | 1 |

Baustellenliste

| Kreisliste | | | | | | | | | |
|------------|--------------|---------------|------|----------------|--------------|-----------|--|-----------------|--------------------|
| Ort | Raumname | Systembauteil | VA | A | Typ / Muster | Rohrlänge | Einstellung Ventil / Durchflussregler / Pumpe | Dämmkennzeichen | Einzelraumregelung |
| | | | cm | m ² | | | | | |
| 02/13 | Bad Nord | FBH01 | 5.5 | 6.81 | A / S | 119.9 | 1.0 l/min | u1 | 1 |
| 02/14 | Diele Nord | FBH01 | 16.5 | 7.44 | A / S | 43.9 | 0.3 l/min | u1 | 1 |
| 02/15 | Zimmer 2 Süd | FBH01 | 5.5 | 5.21 | A / S | 91.8 | 0.5 l/min | u1 | 1 |
| | | FBH01 | 5.5 | 5.21 | A / S | 91.8 | 0.5 l/min | u1 | 1 |
| | | FBH01 | 5.5 | 5.21 | A / S | 91.8 | 0.5 l/min | u1 | 1 |
| 02/16 | Zimmer 1 Süd | FBH01 | 5.5 | 4.74 | A / S | 83.4 | 0.5 l/min | u1 | 1 |
| | | FBH01 | 5.5 | 4.74 | A / S | 83.4 | 0.5 l/min | u1 | 1 |
| | | FBH01 | 5.5 | 4.74 | A / S | 83.4 | 0.5 l/min | u1 | 1 |
| 02/17 | Bad Süd | FBH01 | 5.5 | 4.47 | A / S | 78.7 | 0.6 l/min | u1 | 1 |
| 02/18 | Diele Süd | FBH01 | 16.5 | 7.32 | A / S | 43.2 | 0.3 l/min | u1 | 1 |
| 03/01 | Schlafen | FBH01 | 5.5 | 5.01 | A / S | 88.1 | 0.5 l/min | u1 | 1 |
| | | FBH01 | 5.5 | 5.01 | A / S | 88.1 | 0.5 l/min | u1 | 1 |
| | | FBH01 | 5.5 | 5.01 | A / S | 88.1 | 0.5 l/min | u1 | 1 |
| 03/02 | Ankleide | FBH01 | 5.5 | 5.60 | A / S | 98.6 | 0.6 l/min | u1 | 1 |
| 03/03 | Wohnen/Essen | FBH01 | 5.5 | 6.09 | A / S | 107.1 | 1.1 l/min | u1 | 1 |
| | | FBH01 | 5.5 | 6.09 | A / S | 107.1 | 1.1 l/min | u1 | 1 |
| | | FBH01 | 5.5 | 6.09 | A / S | 107.1 | 1.1 l/min | u1 | 1 |
| | | FBH01 | 5.5 | 6.09 | A / S | 107.1 | 1.1 l/min | u1 | 1 |
| | | FBH01 | 5.5 | 6.09 | A / S | 107.1 | 1.1 l/min | u1 | 1 |
| | | FBH01 | 5.5 | 6.09 | A / S | 107.1 | 1.1 l/min | u1 | 1 |
| 03/04 | Küche | FBH01 | 5.5 | 5.79 | A / S | 101.9 | 1.1 l/min | u1 | 1 |
| 03/05 | WC | FBH01 | 5.5 | 3.04 | A / S | 53.5 | 0.6 l/min | u1 | 1 |
| 03/06 | Flur | FBH01 | 16.5 | 11.30 | A / S | 66.7 | 0.3 l/min | u1 | 1 |
| 03/07 | Gäste | FBH01 | 5.5 | 4.95 | A / S | 87.1 | 0.9 l/min | u1 | 1 |
| | | FBH01 | 5.5 | 4.95 | A / S | 87.1 | 0.9 l/min | u1 | 1 |
| 03/08 | Bad | FBH01 | 5.5 | 4.40 | A / S | 77.4 | 0.4 l/min | u1 | 1 |
| | | | | | | | | | |
| 56 | Kreise | | | 377.05 | | 5249.5 | | | |

Legende

Systeme

Systeme

FBH01 Fonterra Tacker F30-3 Falt PE-Xc 17x2,0 mm (377.0 m²)

Wärmedämmkennzeichen

u1 gegen unbeheizten Raum (377.0 m²)

Einzelraumregelungen

1 Raumthermostat, 230 V Viega 610401

Kreistypen

A Aufenthaltszone (377.0 m²)

Verlegemuster

S Schneckenförmig (377.0 m²)